

Genset	
Model	JHW5-1250GF
Voltage	400/230V
Frequency&Speed	50HZ 1500RPM
Prime Power	1251kW/1564kVA
Standby Power	1377kW/1721kVA

Engine: Baudouin 12M33D1530E310

Alternator:Stamford/Leroy Somer

/Hengsheng

Controller:DeepSea/SmartGen

/DEIF/ComAp

General Engine Data

CE

No.of Cylinders:	16	Displacement:	52.3L
Bore:	150mm	Lube oil:	171L
Storke:	185mm	Consumption:	205g/kw.h
Ratings Definitions	Operating condition		
	1.Unlimited using tim	ne per year	
COP	2.Continuous power	is the maximum powe	er available at a
	constant load factor		
	3.No overload capab	ility is allowed.	
	1.Unlimited using tim	ne per year	
PRP	2.The average load rate is no more than 70% over 24 hours		
	3.Overloading 10% for	or 1h within 12 hours	of operation is allowed.
1. The annual operating time shall not exceed 200h			ceed 200h
	2. The average load rate shall not exceed 70% over 24h operation		
	Cycle		
	3.No overload capab	ility is allowed;\	
4. The acceleration of starting of diesel engines are carried out		jines are carried out in	
	accordance with Q/W	/CG136.13, and there	's no engine
	process. From accele	ration of starting to c	alibration speed shall
ESP be completed within 10s. Natural aspirated diesel engine, w		d diesel engine, when	
	the environment tem	perature is below 5°C	, need to increase
	preheat facilities to e	nsure that diesel engi	ine water temperature
	above 30°C. When er	vironment temperatu	ure over 5°C, no
	preheating facilities a	are required.	
	Supercharged diesel	engine, when the env	vironment
	temperature is below	10°C, need to increas	se preheat facilities to
	ensure that diesel en	gine water temperatu	ire above 30°C. When
	environment tempera	ature over 10°C, no pr	reheating facilities are
	required.		



/	
LTP	1.No ability to overload;
	2. The annual operating time shall not exceed 500h while
	supplying a variable electrical load.
DCP	1.It has 10% overload capacity
	2.Annual run time is unlimited;
	3.Working under variable or continuous load of less than 100%
	4.The power load shall not exceed 70% of the calibration power
	when the device is running continuously.
Descriptions	1.All ratings are based on operating conditions under ISO 8528-1,
	ISO 3046, DIN6271. Performance tolerance of $\pm 5\%$.
	2.Test conditions : 100 kPa, 25°C air inlet temperature, relative
	humidity of 30%, with fuel density 0.84 kg/L. Derating may be
	required for conditions outside these; please contact the factory
	for details.
	3.Power output curves are based on the engine operating with
	fuel system, water pump and lubricating oil pump, without
	battery charging alternator, fan and optional equipment.

Alternator

Pole No.	4-Pole
Exciter Type	Single bearing, Brushless, Self-excited
Power factor	0.8
Voltage adjust range	$\leq 5\%$
Insulation Grade	Н
Protection Grade	IP23/22
Phase / wire	3 phase 4 wires

- ♦ NEMAMG1.JIANGHAO, and ANSI standards compliance for temperature rise and motor starting.
- \diamond Sustained short-circuit current of up to 300% of the rated current for up to 10 seconds.
- ♦ Sustained short-circuit current enabling down stream circuit breakers to trip without collapsing the generator field.
- $\diamond \quad {\sf Self-ventilated and dripproof construction}.$
- \diamond Superior voltage waveform from two-thirds Pitch windings and skewed stator.
- ♦ Digital solid-state.volts-per-hertz voltage Regulator with +1% no-load to full-load regulation.



Control Panel



The control module gives digital readouts of: Generator voltage; Output frequency; Engine speed;

Battery voltage;

Engine hours run.



Dimension:5400*2200*2500mm Weight:9000kg



Dimension:12000*2400*2900mm Weight:12800kg Fuel Tank Capacity:1000-3000L The **control panel** is an Digital Control Module suitable for a wide variety of single, diesel or gas, gen-set applications.

Monitoring an extensive number of engine parameters, the module will display warnings, shutdown and engine status information on the back-lit LCD screen and illuminated LEDs.

The control module has indicators for failure information:

Over speed/Low speed, Emergency stop Low oil pressure; High water temperature Failure to start Battery charger failure

Automatic shutdown occurs under:

Low engine oil pressure; High engine water temperature; Over speed/Low speed; Failure to start after three attempts.

Electrical system

- Maintenance-free and anti-explosion battery
- Standard breaker
- ABB breaker (optional)
- ATS (optional)
- Battery charger (optional)
- GMS monitoring (optional)

Packing

- Wrapping film packaging
- Tray packaging
- plywood box packaging

Jiangsu Jianghao Generator Co.,Ltd

Address: No.1 Xixu Road, Medical High-tech Zone,

Taizhou city, Jiangsu, China Contact Person: Anthony Feng Email: <u>ihfsale@jhgenerator.com</u> WhatsAPP: +86 18652649673

